



# Important Tank System



## Upgrades/Deadlines

- Feb 1, 2010    **Containment for fill not located in dike - Comm 10.410(6)**
- Feb 1, 2010    **Periodic inspections of ASTs - Comm 10.440(1)**
- Feb 1, 2011    **Auto shut-off overfill protection - Comm 10.505(2)(b)**
- Feb 1, 2011    **Leak detection for underground piping from an AST -  
Comm 10.400(4)(a)**
- Feb 1, 2011    **Corrosion protection on underground piping from an AST -  
Comm 10.400(2)(c)**
- Aug 1, 2011    **Overfill prevention on ASTs with fill point not in dike -  
Comm 10.410(9)**
- Dec 31, 2011    **Emergency shut-off for transfers - Comm 10.370**
- Dec 31, 2011    **Secondary containment for transfer operations -  
Comm 10.340(5)**
- Jan 1, 2012    **Designation of Class A, Class B and Class C operators -  
Comm 10.820 (1)**
- Dec 31, 2014    **Secondary containment for Hazardous Substance ASTs -  
Comm 10.350(3)(j)2**
- Dec 31, 2014    **Secondary containment for Hazardous Substance operations -  
Comm 10.350(5)(b)1.b.**
- Dec 31, 2014    **Pipe connection at dispenser shall be in secondary containment -  
Comm 10.400(3)(d); Comm 10.500(5)(d)**
- Dec 31, 2014    **Pipe connections at top of tank shall be in secondary containment -  
Comm 10.500(5)(d)**

# Plan Ahead-Do Not Risk Shutdown

If you are not the operator responsible for these changes, give this notice to the proper individual or corporate official.

If you have questions concerning compliance issues at your facility, contact your petroleum equipment provider or the Commerce inspector in your area.